



Ref. Certif. No.

HU-002442

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Electromechanical contactor for household and similar purposes

## Name and address of the applicant

MAXGE Electric Technology Co., Ltd  
No.299, East Changhong Road, Deqing Economic Zone,  
Wukang, Deqing, Zhejiang 313200, P.R. China

## Name and address of the manufacturer

MAXGE Electric Technology Co., Ltd  
No.299, East Changhong Road, Deqing Economic Zone,  
Wukang, Deqing, Zhejiang 313200, P.R. China

## Name and address of the factory

MAXGE Electric Technology Co., Ltd  
No.299, East Changhong Road, Deqing Economic Zone,  
Wukang, Deqing, Zhejiang 313200, P.R. China

Note: When more than one factory, please report on page 2

## Ratings and principal characteristics

AC-7a, Ue= AC 250V(1P, 2P); AC 400V(3P, 4P); 50/60Hz;  
Ie: 16A for EPC1-16-x, EPC1-16-xM,  
Ie: 20A for EPC1-20-x, EPC1-20-xM,  
Ie: 25A for EPC1-25-x, EPC1-25-xM;  
AC-7b, Ue= AC 250V(1P, 2P); AC 400V(3P, 4P); 50/60Hz;  
Ie: 6A for EPC1-16-x, EPC1-16-xM,  
Ie: 7A for EPC1-20-x, EPC1-20-xM,  
Ie: 9A for EPC1-25-x, EPC1-25-xM;  
Ith: 25A; Ui: 500V; Uimp: 4,0kV;  
Us: AC 24V; 110V; 220-240V, 50/60Hz  
(See Test Report for further ratings)

## Trademark (if any)

MAXGE

## Customer's Testing Facility (CTF) Stage used

---

## Model / Type Ref.

EPC1-16-x; EPC1-20-x; EPC1-25-x;  
EPC1-16-xM; EPC1-20-xM; EPC1-25-xM  
/x=10,20,02,11,30,22,31,40/  
(See Test Report for type nomenclature)

## Additional information (if necessary may also be reported on page 2)

---

## A sample of the product was tested and found to be in conformity with

IEC 61095:2009

## As shown in the Test Report Ref. No. which forms part of this Certificate

1C182019

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.com

Date: 2019-01-15

Signature:

Gabor Kassai

