

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker

Name and address of the applicant

MAXGE ELECTRIC TECHNOLOGY CO., LTD  
No. 299 East Changhong Road, Wukang Town, 313200  
DEQING COUNTY, Zhejiang  
CHINA

Name and address of the manufacturer

MAXGE ELECTRIC TECHNOLOGY CO., LTD  
No. 299 East Changhong Road, Wukang Town, 313200  
DEQING COUNTY, Zhejiang  
CHINA

Name and address of the factory

MAXGE ELECTRIC TECHNOLOGY CO., LTD  
No. 299 East Changhong Road, Wukang Town, 313200  
DEQING COUNTY, Zhejiang  
CHINA

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

see page 2

Trademark (if any)

**MAXGE**

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

EP-DPN4.5K, EP-DPN6K

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

260734-TL3-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2019-10-11

Signature:



B. Megerle



Ref. Certif. No.

**DE1-62666**


**Additional information (if necessary)**

Ue: AC 240 V ; 1P+N (single-pole form factor, N on right side)

In: 2 A, 4 A, 6 A, 10 A, 13 A, 16 A, 20 A, 25 A, 32 A

B and C characteristic; 50/60 Hz

EP-DPN4.5K Icn=4.5 kA; EP-DPN6K Icn=6 kA

Energy limiting class: EP-DPN4.5K: 1 and 3; EP-DPN6K: 3

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2019-10-11

Signature:

B. Megerle