

ATTESTATION OF CONFORMITY

Issued to: MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No.299 East Changhong Road, Wukang Town, Deqing County,
313200 Zhejiang Province, P.R.China

For the product: Moulded-Case Circuit-Breaker

Trade name: MAXGE

Type/Model: SGM6sm-630H, SGM6sm-630M, SGM6sm-400H, SGM6sm-400M,
SGM6s-630H, SGM6s-630M, SGM6s-400H, SGM6s-400M,
SGM6-630H, SGM6-630M, SGM6-400H and SGM6-400M

Ratings: Ue: 380 Vac / 400 Vac / 415 Vac, 50 / 60 Hz
Ui: 1000 V, Uimp: 8 kV
In: 250 A, 280 A, 300 A, 315 A, 350 A, 400 A, 500 A, 550 A, 630 A
3P and 4P (N pole without overcurrent protection)
See annex for further ratings

Manufactured by: MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No.299 East Changhong Road, Wukang Town, Deqing County,
313200 Zhejiang Province, P.R.China

Subject: Type test

Requirements: EN 60947-2:2017, EN 60947-2:2017/A1:2020,
IEC 60947-2:2016, IEC 60947-2:2016/A1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test report no 3316583.50 issued on 2021-05-19.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 02 June 2021

Number: 3316583.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

